

Civil Surgeon Office Tarn Taran

No.CSTT San/2024/78

Date: 10/4/2024

To Whom It May Concern

This is to certify that we have inspected British Victoria School
Geemawal Sahib Tarn Taran After inspecting their Toilets, and other
rooms, we can certify that their Cleanliness and sanitation is good. Their water is
Potable through RO system as per report of Rural Water Supply and Sanitation
Department. This certificate is valid for one year from the date of issue. No Health
Hazard is seen in the premises of the school. There are separate washroom for girls
and boys.

Signature
District Epidemiologist
TARN TARAN
District Epidemiologist

Tarn Taran

Signature

British Victoria School

Principal

British Victoria School

Signature
President

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtltt1@gmail.com

TEST REPORT

Name & Address of Customer : British Victoria school Goindwal sahib , Tarn Taran	Customer Reference No.	No : 207 Dated : 28/03/2024
	Sample Submitted by	Mr. Harpreet Singh
	Date of Sample Receipt	28/03/2024
	Analysis Starting Date	28/03/2024
	Analysis completion Date	29/03/2024
Discipline : Chemical Testing		Group: Water
ULR No.:	Sample Type :	Treated Water
Test Report No.: DWTLTT/2324/00338	Date of Issue :	30/03/2024
Registration no.: DWTLTT/REG2324/00763	Condition of Sample :	Unsealed
Collection Point: Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source: Not Mentioned(Not Mentioned)	Location/Depth :	NA / NA
Village : Goindwal Sahib	Habitation :	Goindwal Sahib
Block: Khadoor Sahib	District :	Tarn Taran
Latitude : Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.65	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	20	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.01	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	16	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness	24	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	6.41	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	1.94	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	3.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Poojika Arora

British Victoria School

Principal

British Victoria School

Harpreet Singh
President

Reviewed and Approved By

Pankaj Kumar

Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Tarn Taran

End of the Test Report